Radio Module Instructions G2-RF-SWMBUS



Specifications

Power supply: 3,6V
Transmission interval: 120 secondi, Lun – Ven, 8 - 17
Transmission frequency: 868MHz
Supplier: GTM
Device Serial Number: Vedi parte inferiore del dispositivo

Installation

To ensure the most efficient transmission possible, we recommend that you install the radio module horizontally, with the antenna perpendicular to the surface. (See Fig. 1)



Fig. 1

Set-up and operation

The Wireless MBus module is supplied switched off.
To switch it on, place a magnet on the cover on the side furthest from the antenna for at least 6 seconds (see Fig. 2).
When the device is switched on, you can see the green and red LEDs flashing through the cover.
The module transmits data every 2 minutes, indicated by the green LED lighting up.

If the module is not activated by the magnet, it will activate automatically after 5 pulses from the input contact.




Fig.2

Disposal

Smart meters contain lithium batteries; therefore, the product falls within the scope of Directive 2012/19/EU on the management of waste electrical and electronic equipment (WEEE). The device must not be disposed of with household waste as it is made up of various materials that can be recycled at appropriate facilities. At the end of its life cycle, ensure the safe removal and responsible disposal of its components, including the recycling of the batteries, in accordance with the environmental regulations in force in the country of installation.
Please contact your local authority to find out the locations of recycling centres that accept this product for disposal and subsequent proper recycling. The product does not pose a potential risk to human health or the environment, but if discarded in the environment, it has a negative impact on the ecosystem.



The symbol of the crossed-out wheelie bin, which appears on the label affixed to the appliance, indicates that this product complies with the regulations on waste electrical and electronic equipment. Abandoning the appliance in the environment or disposing of it illegally is an offence punishable by law

Instructions property of

G2 Misuratori S.r.l.
THE VALUE OF METERING

CERTIFICAZIONE SISTEMA DI GESTIONE DNV ISO 9001 · ISO 14001 ISO 45001

Laboratorio Taratura contatori d'acqua. Certificato di accreditamento n. 01469 - ISO 17025

LoRa Alliance Member